



VANDERBURGH COUNTY ENGINEERING DEPARTMENT

201 Northwest Fourth Street • Suite 306
Old Vanderburgh County Courthouse
Evansville, IN 47708-1358
Phone (812) 435-5773
Fax (812) 435-5676

May 10, 2010

Mr. Paul Elpers
11911 Winery Road
Wadesville, IN 47638

Dear Mr. Elpers:

Based on an inspection of Stonegate Estates Subdivision on May 7, 2010, the items that need to be addressed currently include the following:

1. Install proper erosion control measures around all curb inlets.
2. Remove all sediment from the storm sewer system.
3. Replace the silt fencing in the areas where it has failed and remove in areas where there is stable grass growth.
4. Re-grade swale 'A' between area inlets #507 and #525 to conform to the approved plans, and then establish grass cover.
5. Once item #4 is completed, re-install appropriate erosion control measures around area inlets #507 and #525.
6. Remove the sediment from end sections #511 and #514.
7. The banks around end sections #523 and #524 are in very unstable condition and are failing.

Once these items have been addressed, contact this office so that another inspection can be completed.

Sincerely,

John Stoll, P.E.
Vanderburgh County Engineer

cc: Bill Jeffers, Vanderburgh County Surveyor

file